


NOTES:

1. COORDINATE DUCTING REQUIREMENTS WITH ALL SERVICE AUTHORITIES.
2. MAINTAIN SEGREGATION TO EXISTING AND PROPOSED SERVICES.
3. ALL SPARE CONDUITS TO BE TERMINATED, CAPPED & FITTED WITH POLYPROPYLENE DRAW WIRE.
4. PROVIDE SPARE CoA COMMUNICATIONS DUCT WITHIN COMMON TRENCH FOR FUTURE CCTV NETWORK COVERAGE.

CoA 865 TRENCHES - ROAD & FOOTPATHS

REV	DESCRIPTION	DATE	CONSTRUCTION STANDARD LIGHTING & ELECTRICAL TRENCHES ROAD & FOOTPATHS		 CITY OF ADELAIDE
A	ORIGINAL ISSUE	10/22			
			SHEET NUMBER		REVISION
			LE065		A