


**PARK LANDS - BORED**

FOR PUBLIC LIGHTING UNDER OR ADJACENT TO PATHWAYS  
WHERE CABLE ROUTE IS CLEARLY DEFINED AND  
TRADITIONAL TRENCHING METHODS ARE NOT PRACTICAL  
AND/OR MAY CAUSE HARM TO EXISTING VEGETATION.  
FOR PREFERRED METHOD OF CABLE POSITIONING IN PARK  
LANDS, REFER CoA 866.

**NOTES:**

1. COORDINATE DUCTING REQUIREMENTS WITH ALL SERVICE AUTHORITIES.
2. MAINTAIN SEGREGATION TO EXISTING AND PROPOSED SERVICES.
3. ALL SPARE CONDUITS TO BE TERMINATED, CAPPED & FITTED WITH POLYPROPYLENE DRAW WIRE
4. PROVIDE PERMANENT METAL ROUND CABLE MARKERS WITH CONCRETE SURROUND AND DIRECTION ARROWS IN ACCORDANCE WITH AS/NZS 3000 TO CLEARLY SHOW FULL EXTENT OF UNDERGROUND CABLING.

**CoA 867** **BORED TRENCHES - PARK LANDS**

REV	DESCRIPTION	DATE	<div>CONSTRUCTION STANDARD</div> <div>LIGHTING &amp; ELECTRICAL</div> <div>BORED TRENCHES</div> <div>PARK LANDS</div>	<div>CITY OF ADELAIDE</div>	SHEET NUMBER	REVISION
A	ORIGINAL ISSUE	10/22				
				LE067	A	